Certificate of Performance

On this date the cleanroom facilities of

Oliver Healthcare Packaging Company 905 Pennsylvania Boulevard Feasterville, PA 19053

Have been tested in accordance with NEBB Procedural Standards for Certified Testing of Cleanrooms to meet the following air cleanliness classification requirements of International Standard ISO 14644-1:2015 during both "operational" & "at-rest" states.

Zone #1 Slitting - ISO Class 8 at 0.5 & 1.0 μm Zone #1 Gowning - ISO Class 8 at 0.5 & 1.0 μm

NEBB Certified Firm: Air Filtration Management

Phone: (610) 867-3869

www.airfiltrationmgmt.com
NEBB Certification Number: 3898

NEBB CPT Professional: Michael A. Wieder

Signature: Michael Cile

Test Date: March 2024 Retest Date: March 2025

National Environmental Balancing Bureau



