



CERTIFICATE OF COMPLIANCE

Awarded to

Oliver-Tolas Healthcare Packaging B.V.

Spurkt 1, 5804 AR Venray

Cleanroom Hall 3

✓ MAL	0.01	ISO Class 8
✓ Inkroom	0.02	ISO Class 8
✓ Slitter	0.03	ISO Class 8
✓ CI press	0.04	ISO Class 7
✓ MAL	0.05	ISO Class 8
✓ Lids/pouch/RZC	0.06a/b	ISO Class 7
✓ Gowning	0.08	ISO Class 8

As per requirements of ISO 14644-1:2015, the designated areas listed above have met their respective acceptance criteria under At Rest Condition, unless specified otherwise, at $\geq 0.5 \mu\text{m}$ & $\geq 5.0 \mu\text{m}$. Testing was performed as outlined in the above standard and the results are attested to in Report: **NL/28001/25/HVB dd. 08 January 2025**

Presented by
Mevr. Ir. M. (Marjolein) Rijpkema
Director

Kuipers PHF Services B.V.
0492-578 600 | info@kuipers.nl

Date of certification:
31 January 2025