

# *Certificate of Performance*

*On this date the cleanroom facilities of  
Oliver Healthcare Packaging Company  
905 Pennsylvania Boulevard  
Feasterville, PA 19053*

*Have been tested in accordance with NEBB Procedural Standards for  
Certified Testing of Cleanrooms to meet the following air cleanliness classification  
requirements of International Standard ISO 14644-1:2015 during both  
“operational” and “at-rest” occupancy states.*

*Zone #1 Slitter Area & Gowning - ISO Class 8 at 0.5, 1.0 & 5.0  $\mu$ m  
Zone #3 Slitter 17 Area - ISO Class 8 at 0.5, 1.0 & 5.0  $\mu$ m*

*NEBB Certified Firm: Air Filtration Management*

*Phone: (610) 867-3869*

*[www.airfiltrationmgmt.com](http://www.airfiltrationmgmt.com)*

*NEBB Certification Number: 3898*

*NEBB CPT Professional: Michael J. Kelly*

*Signature: *

*Test Date: Nov. 2024      Retest Date: Nov. 2025*

**National Environmental Balancing Bureau**

